



# Envirochem Testing & Consultancy LLP

(GOVT. APPROVED LAB)

(An ISO 9001 : 2015, ISO 14001 : 2015, ISO 45001 : 2018 Certified Lab)

Plot No. 165, 1st Floor, Sector-25, Part-II, HUDA, Panipat-132103, Hr.

M. : +91 90348 91129, 89501 75388

Email : envirochemtestinglab@gmail.com

## TEST REPORT

| Report No.                                                             | ETL/ PNP/WW0702 | Report Date                                                                                  | 07.03.2026 | Doc No. | ETL/QF/7.8/01 |
|------------------------------------------------------------------------|-----------------|----------------------------------------------------------------------------------------------|------------|---------|---------------|
| Issue to:<br>M/s Haat Supreme Wastech (P) Ltd<br>Bajida Jattan, Karnal |                 | Party's Ref No: Nil<br>Work Order No: WW26030702<br>Period of Testing: 02.03.2026-07.03.2026 |            |         |               |

### SAMPLE PARTICULARS

|   |                                     |   |                       |
|---|-------------------------------------|---|-----------------------|
| 1 | Type of sample                      | : | WASTE WATER           |
| 2 | Point of Sample Collection          | : | ETP Inlet/Outlet      |
| 3 | Date of sample collection/ received | : | 02.03.2026            |
| 4 | Purpose of analysis                 | : | Monitoring purpose    |
| 5 | Sample collected/ supplied by       | : | By Lab Representative |
| 6 | Sample Quantity                     | : | 2 Litre Each          |
| 7 | Method of Sampling                  | : | As Per IS 3025        |

### TEST RESULTS

| Sr. No. | Parameters                    | Inlet | Outlet | General Std. Limits For Discharge | Protocol used         |
|---------|-------------------------------|-------|--------|-----------------------------------|-----------------------|
| 1.      | Colour (Hazen)                | 209   | 20     | -                                 | IS 3025 (P-4): 2021   |
| 2.      | Odour                         | Foul  | Mild   | -                                 | IS 3025 (P-5) : 2018  |
| 3.      | pH                            | 6.11  | 7.41   | 5.5 to 9.0                        | IS 3025 (P-11) 2022   |
| 4.      | COD, mg/L                     | 502   | 37     | 250                               | IS 3025 (P-58) 2023   |
| 5.      | BOD at 27°C for 3 Days, mg/L  | 192   | 8.6    | 30                                | IS 3025 (P-44) 2022   |
| 6.      | Total Suspended Solids, mg/L  | 204   | 6      | 100                               | IS 3025 (P-17) 2022   |
| 7.      | Specific Conductance, µmho/cm | 9041  | 1930   | -                                 | IS 3025 (P-14) : 2013 |
| 8.      | Oil & Grease, mg/L            | 4.8   | <4     | 10                                | IS 3025 (P-39) 2021   |

Remarks: 1. Analysed Parameters meet the General Standards Limits for discharge.

2. All Parameters are covered under NABL Scope .

\*\*\*\*\*End Report\*\*\*\*\*

Analysed By  
Chemist

Reviewed & Verified By  
Neha Singh (T.M)

Authorised By  
Dr. Rajender Kumar

