



Form J

(See Rule 36)

Report No-274

Type of Sample: Legal

Dated: 29.05.2026

I, hereby, certify that I, Aparnesh Kaushik Board Analyst duly appointed under sub section (3) of section 53 of the Water (Prevention and Control of Pollution) Act, 1974 (6 of 1974) received on the 18th day of May, 2026 from Sh. Siddhant Rastogi, AEE a sample of M/s Haat Supreme Wastech Pvt. Ltd. Near Railway Crossing, Bajida Jattan, Karnal collected on 18th day of May, 2026 for analysis.

I further certify that I have analyzed the aforementioned sample on 18th day of May, 2026 to 29th day of May, 2026 and declare the result of the analysis to be as follows:-

Sr. No.	Parameter Name	Result	Result	Limit	Test Method
1.	Sample Code	475	476		
2.	Sample Collected from	Inlet of ETP	Outlet of ETP		
3.	Color	Hazy	A.Colourless	-	
4.	Odour	Mild	A.Odourless	-	
5.	pH value at 25°C	7.15	7.64	5.5-9.0	APHA 4500-H ⁺ (B) (24 th Ed)
6.	Biological Oxygen Demand (mg/l)	220.0	6.5	30	IS:3025 (Part-44)
7.	Chemical Oxygen Demand (mg/l)	744.0	36.0	250	APHA 5220 (B) (24 th Ed)
8.	Total Suspended Solids mg/l	196.0	8.0	100	APHA 2540 (D) (24 th Ed)
9.	Oil and Grease (mg/l)	22.5	BDL(DL=02)	10	APHA 5520 (B) (24 th Ed)
10.	Conductivity at 25°C (µS/cm)	5243.0	811.0	-	IS:3025(Part-14)

The condition of the seals, fastening and container on receipt was as follows:-

The container had its seal intact and in order, slip on the container had the signature of the representative of the industry and the Board.

Signed this 29th day of May 2026


Board Analyst

Haryana State Pollution Control Board Laboratory,
C-11, Sector-6, Panchkula, Haryana

To

The Member Secretary, HSPCB, Panchkula
Regional Office, Karnal

This test report relate only to the particular sample submitted for testing.

End of the Report